

CERTIFICATE ENEC/FI 2016070



Our Ref. 285858-1

Product	Control gear for LED modules
Rating and principal characteristics	220-240V; 50/60Hz; 0,93...0,96; Constant current 350mA/10...50V or 500mA/10-50V or 700mA/10-40V; Uout (max) 60V; Pout (max) 28W; SELV; tc 75°C; ta -20...+50°C or -20...+45°C for independent use
Trade mark (if any)	Helvar
Types	LC1x28-AN LC1x28-AN+LC1x30-SR
Name and address of the licensee and the manufacturer	Helvar Oy Ab Keilaranta 5 FI-02150 ESPOO FINLAND
Is in conformity with	EN 61347-2-13:2014 + A1:2016 EN 61347-1:2015 EN 62384:2006 + A1:2009
As shown in the Test Report(s) No(s)	285858-1_A, 285858-1_B
It is authorized to use of the marks	ENEC 16 and FI

Validity This certificate is valid until 03 November 2021 provided that the Conditions for ENEC and FI certification are met. This certificate includes the right to use the ENEC 16 and FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

With the following limitations -

Date of issue 03 November 2016

SGS Fimko Ltd

Signature

Kari Vesterinen

Product Line Manager



This certificate has 3 pages



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Page No.: 2 of Certificate No.: ENEC/FI 2016070

Additional information

Type LC1x20-AN+ LC1x30-SR is equipped with optional strain relief device and is for independent use.



Is based on test / Our ref.

285858-1_A, 285858-1_B